


Queries from the Bidder for the EOI for setting up solar power plant at Baiyappanahally Depot for which discussion with the participants were held on 16.03.2013 at 11.00hrs at conference hall, BMRCL.

SL No	Queries/question/observation/comments/ Amendments sought	Question sought by	BMRCL remarks
1	The technical criteria mentioned of at least 500KW of installation in India. Is it necessary to have installations of said capacity in India only? Can outside experience preferred for the project.	Godrej & Boyce Mfg. Co. Ltd	Overseas experience acceptable- refer corrigendum issued
2	The technical criteria of 500KW grid connected roof top projects should be done by the bidder. Is it necessary to have roof top systems only or ground mounted grid connected system experience could also be counted or not ?	-DO-	No change in EOI document
3	The technical criteria of 500KW grid connected roof top projects in India. Can we qualify with 100KW off grid solar plant Installation?	-DO-	No change in EOI document
4	Consortium of two members can be made Can the financial bidder be the lead bidder for the project?	-DO-	Yes financial bidder can be the leader- refer corrigendum issued
5	Role of carbon financing and benefits to be explored by bidder. Who will be the owner of carbon credits? Is it Developer or BESCO	-DO-	Concessionaire.
6	Roof for installation of plant will be provided by BMRCL. Do we need to pay the rent for the roof which is leased out?	-DO-	BMRCL is exploring the possibility of either rental or revenue share or a mix of both, participants of EOI may suggest the modalities
7	The CAD files for each site and roof plan with details will be required for preparing the technical proposal. When can this be shared?	TATA Power Solar	Would be shared at RFP stage
8	What will be the maximum wind speed requirement for modules mounting structure (km/hr)?	-DO-	Would be shared at RFP stage
9	What will the allowed total weight at roof top in kg/m ² ?	-DO-	Would be shared at RFP stage
10	Is chipping allowed on the RCC floor?	-DO-	Chipping not allowed since other options are available.
11	What will be the output voltage range?	-DO-	As provided in EOI
12	Can we offer string inverters?	-DO-	Concessionaire's choice subject to technical acceptability.

13	Can we offer fixed tilt structures?	-DO-	Concessionaire's choice subject to technical acceptability.
14	Is higher DC to AC ratio acceptable for inverter selection?	-DO-	Concessionaire's choice subject to technical acceptability.
15	What will be the distance from terrace floor to control room location?	-DO-	As available in site.
16	Is there any AMC or CMC contract specified in the requirement?	-DO-	It is a BOOT model for 15years and Concessionaire has to operate and maintain.
17	Do we need to supply any spare list?	-DO-	It is a BOOT model for 15years and Concessionaire has to operate and maintain.
18	What are the warranty conditions?	-DO-	It is a BOOT model for 15years and Concessionaire has to operate and maintain.
19	Is there an energy generation commitment?	-DO-	It is a BOOT model for 15years and Concessionaire has to operate and maintain.
20	<p>Request to change clause- i of the Technical eligibility: Experience in Development of grid connected solar power projects of at least 500 kW Cumulative capacities any where in the world.</p> <p>Request to change clause- iii of the Technical eligibility: Should have erected, tested and commissioned at least one roof top grid connected solar photovoltaic (SPV) power plant of minimum 100 kW in any location anywhere in the world and total aggregate capacity of solar PV of 500 kW roof top grid connected SPV power plants anywhere in the world. along with all required associated, allied, auxiliary equipment complete in all respect. The power plants should be in successful operation for minimum period of one year as on the date of 01.04.2013.</p> <p>Request to change clause- ii of the Financial eligibility: Net worth in case of corporates and individuals shall be at least INR 1 crore in last year for either of the member in case of consortium.</p>	<p>Ravano Green Power Pvt Ltd.</p> <p>-DO-</p> <p>-DO-</p>	<p>Yes. Agreed. - refer corrigendum issued</p> <p>Yes. Agreed. - refer corrigendum issued</p> <p>In case of consortium, one of members net worth shall be at least INR 1 core and the net worth of the other person should be positive</p>


EE R3 25/3/13